



Rethinking Seasonal Storage with a TT-Link

A Trans-Tasman Subsea HVDC Link as an Alternative to Hydrogen

Hadi Vatankhah Ghadim, E. Grant Read, Rebecca Peer, Jannik Haas
Sustainable Energy Research Group (SERG), University of Canterbury

2025 EPOC winter workshop – 5 Sep 2025

New Zealand 2024 Dry Winter: Managed, Not Solved

To this day, the supply shortage has been managed with variable hydro and thermal reserves

NEW ZEALAND / ENERGY

Hydro storage lake levels lower than usual, Transpower says

9:57 am on 1 August 2024

Share this     

Tight gas supply, low lake levels drive up wholesale power prices

THE CONVERSATION


Academic rigour, journalistic flair



NZ energy crisis: electricity demand will jump as NZ decarbonises – can renewable generation keep up?

Published: August 27, 2024 7:56pm BST

Supply-demand plot: Aug. 29th, 2024



1.1 Million Tonnes of Coal: NZ's Dry-Year Insurance for 2025

Gentailers (led by Genesis) agree to stockpile coal at Huntly Power Station



News Life Radio Podcasts Video Te Ao Māori Pacific IndoNZ 中文


New Zealand World Politics Pacific Te Ao Māori Sport Business Country Local Democracy Re

NEW ZEALAND / BUSINESS


Gentailers agree to stockpile coal at Huntly Power Station

11:39 am on 4 August 2025

Share this



Dwindling natural gas supply



Increasing demand (MBIE)

Solution: Onslow Lake Battery Project. **Failed** due to...

High estimated investment cost (~16 Billion NZD)


Higher round-trip losses

Virtual energy storage... over the ditch

An avant-garde energy transmission solution to solve the dry winter issues



Trans-Tasmanian HVDC link



** EuroAsia Interconnectors (Greece-Cyprus-Israel)*

TRL: Fairly high (7-8)

- Cables & converters: **9** (mature)
- Deep cable burial/laying: **9** (mature) – SAPEI HVDC link (IT)
- Long-distance cabling: **8** (beyond pilot tests) – Viking Link (DK-UK)

How much are the per-flow losses for a TT-Link?

Quadratic loss curves for the operational and planned projects

$$\ell(q) = \ell_1 \cdot q + \ell_2 \cdot q^2$$

Quadratic in power
linear in distance
 $I^2 R \rightarrow I \propto q, R \propto D$

q : Transmitted electricity (MW)


ℓ_1 : Linear loss coeff. (1.8 % conversion losses)

* Fixed conversion loss (MW_{loss} per $MW_{transmitted}$) assumed to be near zero.

$$\ell_2 = c_1 \cdot D$$

D : Distance (km)

c_1 : Distance-based loss components




* Trans-Tasman Link losses are calibrated with the Viking Link.

How much are the per-flow losses for a TT-Link?

Marginal loss curves for the operational and planned projects


$$\frac{d\ell(q)}{dq} = \ell_1 + 2 \cdot \ell_2 \cdot q$$



* Trans-Tasman Link losses are calibrated with the Viking Link.


Observed electricity price differences

There is a potential for an energy arbitrage between the North Island (NI) and Queensland (QLD)



Loss-adjusted price differences between NI and QLD

When can we export to QLD? When can we import? And when is it not economic to use the link?



Blue: NI cheaper (export from NZ),
White: Not suitable for trading,
Red: QLD cheaper (export to NZ)

Our hybrid approach in a nutshell

When to import? How much a MWh from the link would cost? How the least-cost future system looks like?

- 1st step: Market price-based analysis (we've done this for QLD/NZ trade potential)

We assumed no market response; thus, we used the market data to get the upper bound for the analysis (potentially, over-estimating the benefits)

- 2nd step: Modelling using PyPSA-NZ (We're doing this for NZ – import-only)

Understanding system-level impacts of the TT-Link

Optimising the future energy system considering the presence of TT-Link using PyPSA-Earth framework

PyPSA-Earth-NZ Setup


Preparation

- Renewable timeseries and potentials (IRENA)
- Infrastructure detection (OSM)
- Weather data preparation (ERA5 satellite)
- Data-driven demand forecast (e.g., SSP 2-2.6)
- Fusion of datasets for optimization
- Cleaning, processing, and preparation
- Calibration with national statistics



Model setup

- Transmission network
- Substations and transformers
- Carriers (production, storage)
- Gas, heat, and H₂
- Clustering configurations
- Model validation
- etc...



Generation capacity (GW) - 2020

	Hydro	Solar	Wind	Geothermal	Oil	Coal	OCGT	CCGT
Actual data (MBIE)	5.44	0.16	0.69	1.04	0.19	0.5	0.54	0.76
PyPSA-NZ	5.29	0.00	0.73	1.05	0.15	0.75	0.45	0.79
REMIX-NZ	5.34	0.00	1.06	1.04	0.17	0.11	0.54	0.76
EP-ALISON-LUT	5.44	0.17	0.69	1.04	0.19	0.42	1.73	

Scenario: Trans-Tasman Link

Assumptions

Linked points:
South Auckland (NZ) to Northern Brisbane (AU - QLD)

Link distance: 2500 km

Assumed transmission capacity: 1-5 GW


Transmission losses: 17 % (round-trip)

Capital expenditure: 493 EUR/MW/km

Project lifetime: +50 years



Discount rate: 5 %

* Based on existing projects (e.g. Viking Link, North Sea Link)





Preliminary Results

Output



What does the 2030 system look like?

A 1-GW bi-directional TT-Link reduces the total grid investment requirements by 13% on average.



Overall GEP savings:


~ 440 Million EURs

Required capital for TEP within NZ:

~ 245 Million EURs

What does the 2030 system look like?



A 1-GW bi-directional TT-Link provides 0.7 TWh of virtual storage for New Zealand during winter.



1 GW TT-Link operational stats:

- Utilisation rate: **0.3737**
- Average annual LCOE:

204.04 EUR/MWh



1-GW or more? - What should we aim for?


The highest utilisation rate (~42%) is recorded when there is a link with 2-3 GW capacity.




1-GW or more? - What should we aim for?

The lowest LCOE (~182 EUR/MWh) is recorded when there is a link with 2-3 GW capacity.

LCOE comparisons for different techs



Solar and wind expanded capacity comparison



What does the 2030 system operation look like?

A 2-GW HVDC interconnector provides an annual hydro use offsetting by around 215 GWh.



Further details to be included...

What improvements does the PyPSA-NZ model need?

Overall simplifications:

- 1) No price response from QLD (infinite elasticity – the investment response would be in a way that maintains the current price patterns – disequilibrium?).
- 2) NZ load forecast is based on the SSP 2-2.6 scenario (no response to price changes induced by link investment).
- 3) Simplified assumptions on the line configurations (based on the operational cases globally).
- 4) Improving hydro modelling in PyPSA.

Potential refinements on the current hybrid modelling approach:

- 1) Assuming the elasticity using the market bid/offer curve for NZ (decrease profitability)
- 2) Increasing the volatility in the market (increase profitability)

Q&A

SE Sustainable
RG Energy
Research
Group

UC
UNIVERSITY OF
CANTERBURY
Te Whare Wānanga o Waitaha
CHRISTCHURCH NEW ZEALAND

Thanks for your attention!